

CHOOSING THE RIGHT FIRE ALARM SYSTEM

Feature	SITENET	SITEPROTECT	SITEEVAC+	LinkaBull	SITEEVAC
EN 54	EN 54-2,3,4,5,7, 11,18,23,25	EN 54-5 & 7 *	EN 54-5 & 7 *	✗	✗
Max Zones	32	15	3	1	1
Max Devices	511	480	50	15	1
Ranges Includes Fire Detection	EN54-5 & 7	EN54-5 & 7 *	EN54-5 & 7 *	✗	✗
Fault Detection	Within 20 seconds	After 18hrs *	✓	✗	✗
Missing Node Detection	Within 300 seconds	After 24hrs *	✓	✗	✗
First Aid Option	✓	✓	✗	✗	✗
ARC Connection	✓	✓	✗	✗	✗
Cygnus ALERT	✓	✗	✗	✗	✗
Device Battery Life	Over 3 years	2 Years	12 months	12 months	12 months
Device Battery Back Up	✓	✗	✗	✗	✗
Control Panel	Mandatory	Optional	Optional	✗	✗
Panel Battery Backup	72hrs min	15days**	7days	N/A	N/A
Applications	All construction Specifically for Sites requiring Compliance to Fire Prevention on Construction Sites 10th Edition - JCoP and HSG168 for Temporary Accommodation Units	All construction	General housebuilder	Small housebuilder	Homebuilder

* When used with a Control Panel

** CYG1 15days. Reduced to 72hrs when used with Autodialler

+ Detector Heads are compliant to quoted EN 54 standards

Note : PIR Functionality available with SITEPROTECT



BULL

**EXCELLENCE ON EVERY SITE,
AS STANDARD**

Contact Us:
01432 371170
sales@bullproducts.co.uk
www.bullproducts.co.uk

