



Flammable Storage Cabinets



- All cabinets are compliant with DSEAR 2002—HS(G) 51, 1990 Factory inspectorate certificate of approval, No 1 parts 3 & 4—COSHH
- High visibility powder coated finish with appropriate warning labels.
- Welded construction in 0.9mm thick steel
- Designed to maintain integrity for 30 minutes
- Supplied with adjustable spillage trays and liquid tight sump
- Doors are rebated and secured by chrome 3-way locking handle
- Stand (CABS01) for use with CABTF02 & CABTF03
- Designed for laboratories, hospitals, factories, workshops and many other environments which may contain hazardous and flammable substances.

Specification	CABTF01	CABTF02	CABTF03	CABTF04	CABTF05	CABTF06	CABTF07	CABS01
Fire Rating	30 mins	30 mins	30 mins	30 mins	30 mins	30 mins	30 mins	-
Material	Powder Coated Steel	Powder Coated Steel	Powder Coated Steel	Powder Coated Steel	Powder Coated Steel	Powder Coated Steel	Powder Coated Steel	Powder Coated Steel
Height	900mm	700mm	900mm	1800mm	1800mm	1200mm	700mm	550mm
Width	460mm	900mm	900mm	900mm	1200mm	900mm	350mm	900mm
Depth	460mm	460mm	460mm	460mm	460mm	460mm	300mm	460mm
Colour	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow	Yellow
Standards	DSEAR 2002- HS(G) 51	DSEAR 2002- HS(G) 51	DSEAR 2002- HS(G) 51	DSEAR 2002- HS(G) 51	DSEAR 2002- HS(G) 51	DSEAR 2002- HS(G) 51	DSEAR 2002- HS(G) 51	DSEAR 2002- HS(G) 51

Bull Products Ltd

Beacon House, 4 Beacon Road
Rotherwas Industrial Estate
Hereford, HR2 6JF

0844 669 1111
sales@bullproducts.co.uk
www.bullproducts.co.uk

Securing your safety